



Certificate of Compliance

Certificate: 2315228

Master Contract: 242176

Project: 2315228

Date Issued: July 9, 2010

Issued to: Lumeta Inc

A Subsidiary of DRI Companies
17182 Armstrong Ave
Irvine, CA 91614
USA
Attention: Erwang Mao

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Brij Aggarwal

Issued by: Brij Aggarwal, P.Eng.

PRODUCTS

CLASS 5311 10 - POWER SUPPLIES - Photovoltaic Modules and Panels

CLASS 5311 90 - POWER SUPPLIES - Photovoltaic Modules and Panels - Certified to US Standards

Photovoltaic Panels with maximum system voltage of 600 V dc and Class C fire class rating, Model series PowerPly LPPxxxA (where XXX is the power output from 360 W to 440 W) with the following electrical ratings (typical at 400 W output) @ Standard Test Condition (STC):

Power Output: 400 W

Operating Voltage: 82.0 V dc

Open Circuit Voltage: 92.0 V dc

Short Circuit Current: 5.36 A

Current at Rated Operating Voltage: 4.83 A



Certificate: 2315228

Master Contract: 242176

Project: 2315228

Date Issued: July 9, 2010

Notes: Rated electrical characteristics are within +/- 10% of measured values at Standard Test Conditions of 100 mW/cm² irradiance, AM 1.5 spectrum, and 25°C.

APPLICABLE REQUIREMENTS

ULC/ORD - C1703-01 - Flat-Plate Photovoltaic Modules and Panels

UL 1703-3rd Ed - Flat-Plate Photovoltaic Modules and Panels